

Raport de inspectie Nr. **PBZ-0017865R**

din: **07-JAN-2013**

ora: **14:41**

Produsul: Combustibil termic lichid
Fabricat de OMV Petrom S.A. - membru OMV Grup in rafinaria Petrobrazi Ploiesti

Lotul: 2601PE0203 L4

Comanda: nr.1 din: 07.01.2013

Proba din: 07.01.2013 09:00 prelevata conform: EN ISO 3170

Este conforma cu: R 42_Ed 2 februarie 2011


Caracteristica	UM	Valoare prevazuta	Valoare determinata	Metoda
Densitatea la 15 gr C	kg/m3	<=935.00	926.50	ASTM D7042
Continut de sulf total	% m/m	<=1	0.28	ASTM D2622
Punct de curgere	°C	<=5	-18	ASTM D97
Condensat la 250 gr C	%V/V	<=35	34	SR EN ISO 3405
Continut de cenusa	% m/m	<=0.15	0.026	SR EN ISO 6245
Punct de inflamabilitate	°C	>=55	68	SR EN ISO 2719
Carbon rezidual	% m/m	<=5	0.022	SR ISO 10370
Continut de apa	% m/m	<=0.2	0.2	ASTM D95
Aciditate			lipsa	ASTM D1093
Apa si sediment	% m/m	<=1	0.22	ASTM D95+ASTMD473
Vascozitate la 20°C	cSt	<=7.5	4.325	ASTM D7042
Putere calorifica inferioara	kcal/kg	>=9650	9800	ASTM D240

Informatii aditionale pentru intocmire factura

Dens la 15 gr C corectata in aer (kg/m3)	925.40
Densitatea la temperatura probei (kg/m3)	923.20
Temperatura probei (grade C)	20.00

Sef Control Calitate / responsabil delegat

Vasile Elena



OMV PETROM S.A.
Stampila PETROBRAZI
CONTROLUL CALITĂȚII



MOCANU FELICIAN NICU
C.I. Seria RT Nr. 050056
CNP. 1750913434546